


Space between pressure plate and supporting column should be kept free from fixed installations!





## FRAME PLATE

Recommended free space for opening and closing to be applied on both sides

39 \*) / 24 \*\*)-

Free space can be reduced to this distance on one of the sides





**TIGHTENING BOLTS** 

 $4 \times M24$ , L = 12.9 in  $3 \times M24$ , L = 12.9 in

APPROX. OUTER DIMENSIONS LENGTH 22.4 in **WIDTH** 18.9 in HEIGHT 41.3 in

APPROX. WEIGHTS NET WEIGHT, EMPTY

DESIGN TEMPERATURE

598 lb WEIGHT FULL OF WATER 627 lb PLATE MATERIAL PLATE THICKNESS

**GASKET** 

ALLOY 316 0.5 mm NBRP ClipGrip™

**OPERATING** 

PRESSURE MAX. TEMP.

TEST

195 psi

195 psi

MIN.

32.0 °F

32.0 °F

A-A: ALLOY 316

**HEAT EXCHANGED** 2,830 kBtu/h NO. OF UNITS SIDE TEMP. OUTLET TEMP. FLOW RATE | PRES. DROP **MEDIA** INLET S1 MH S2 MH S3 ML 40.0 °F S4 ML

www.alfalaval.com

**DRAWING** 

GASKETED PLATE HEAT EXCHANGER

**ASME** Code Section VIII Div.1 MAWP 150 psi at 266 °F 32.0 °F at 150 psi **MDMT** 

Designed and constructed in accordance with the 2019 ASME Code.

T10B 20 PL

MAX.

150 psi

150 psi

**DESIGN PRESSURE** 

MIN.

0 psi

0 psi

Do not use this drawing for foundation bolting or piping layout

MAX.

266 °F

266 °F

DATE 5/24/21

REVISION

ASME B16.5 Class 150 NPS 4

S1, S2, S3, S4 \_\_\_\_6.18

Ø3.94

Ø3.78